



Government Of West Bengal
Office Of The Divisional Fire Officer,Nadia
West Bengal Fire & Emergency Services
Azad Hind Sarak, P.O.:- Ghurni, P.S.:- Kotwali, Pin :- 741103

Memo no.:IND/WB/FES/20182019 /21439

Date: 11-01-2023

From:
Divisional Fire Officer,Nadia
West Bengal Fire & Emergency Services

To: SUSMITA COLLEGE OF EDUCATION
MOUZA-DAKSHIN BAHIRGACHI,JL-104,PLOT-714 to 718,KH-2046,VILL-BAHIRGACHI,PS-
NAKASHIPARA,NADIA,741154.

Sub: Fire Safety Certificate for Existing construction of G + III Storied Educational building under group of Educational Institution in the name & style "Susmita College of Education" at the premises No. Mouza – Dakshin Bahirgachi, JL No. 104, Plot No. 714, 715, 716, 717 & 718, Khatian No. 2046, Vill:- Bahirgachi, PO:- Bahirgachi, PS:- Nakashipara, Dist:- Nadia, Pin:-741154,, West Bengal.

This is in reference to your application no. 0125189221000094 dated 16-12-2022 regarding the Fire Safety Certificate for Existing construction of G + III Storied Educational building under group of Educational Institution in the name & style "Susmita College of Education" at the premises No. Mouza – Dakshin Bahirgachi, JL No. 104, Plot No. 714, 715, 716, 717 & 718, Khatian No. 2046, Vill:- Bahirgachi, PO:- Bahirgachi, PS:- Nakashipara, Dist:- Nadia, Pin:-741154,, West Bengal.

The performance of the Fire Fighting System as incorporated in the buildings were tested at random and found satisfactorily working condition. In view of the above this office is releasing the Fire Safety Certificate for occupancy of the aforesaid building.

Recommendation:

- 1.All the Fire Safety Recommendations which was issued vide this Office Memo No. IND/WB/FES/20182019/21439, Dated 07-03-2019 be followed strictly at all time.
- 2.Driveway must to be free of anytime of obstruction for EASY movement of fire Appliances. No parking will be allowed on the driveway.
- 3.The interior finish decoration of building shall be made with low flame spread materiel confirming I.S.I. specification.
4. To eliminate risk of Fire Hazards, Good House Keeping both for insides and outside of the Building shall be strictly maintained.
- 5.Existing Electrical wiring of the whole building shall have to be carefully checked for any wear and tear in them, particularly lines above false ceiling & ducts.
- 6.A fire control room including a close circuit T.V. system will have to be installed which will observe all the floor of the Building.
- 7.The notice of Fire Fighting equipments and Evacuation plan shall be maintained and displayed at all venerable places of

the Building.

8.The Employees and security staff shall be conversant with installed Fire Fighting Equipments of the building and to operate in the event of Fire and Testing.

9.Mock Fire practice evacuation drill shall be performed periodically with participant of all the occupants of the building.

10.Main and meter room shall be protected with co2 or DCP Fire Extinguishers confirming I.S. Specifications.

11.First-Aid Fire Fighting system shall be provided as per I.S. Specification.

12.Arrangement shall have to be made for regular checking, testing and maintenance, of all the Fire Fighting installation of the Building to keep them in perfectly good working Condition at all the time.

13.If required the old line shall have to be replaced with new lines the cables shall always be laid in M.S. conduit pipes continuously bonded to the earth.

14.Periodical Flashing of water in hydrants pipe line shall be made to maintain the efficient working performance of above mentioned system.

15.Fire Safety audit to be conducted at regular interval and to be recorded in the fire prevention maintenance register.

16.Existing Lifts shall be treated as Fire Lift in case of Emergency.

17.Transformer & switch Gear room (if applicable) shall be protected with CO2 or D.C.P. Fire Extinguisher conforming I.S. Specification.

18.This Fire Safety Certificate is valid for Three years and have to be renewed every three years interval from the date of Issue of this letter. In every three years Certificate is to be obtained from the Director General, West Bengal Fire & Emergency Services, regarding the Preformance of all the life & Fire Safety arrangements and installation of the Building.

19.Any deviation or changes the building in respect of the approved plan drawing, without prior permission from this office, this fire safety certificate will be treated cancelled automatically.

Divisional Fire Officer,Nadia
West Bengal Fire & Emergency Services

Memo No.:IND/WB/FES/2019/21439